

RESOLUTION NO. 89- 235

WHEREAS, The St. Johns County Courthouse is dependent on fuel oil for heating purposes, and

WHEREAS, the fuel tank for the storage of fuel for the Courthouse was installed circa 1968-69, and


WHEREAS, the Environmental Protection Agency and the Department of Environmental Regulation require certain standards for underground storage tanks, and

WHEREAS, the standards mentioned above require replacement or retrofitting by the end of 1989 for all fuel storage tanks installed prior to 1970

NOW THEREFORE BE IT RESOLVED, that the Board of County Commissioners hereby authorize the County Administrator to contract with Capital Petroleum Equipment Company, Jacksonville, Florida to inspect, reline the inside, and install monitoring wells for the Courthouse's 10,000 gallon underground fuel storage tank at a price not to exceed \$10,000.00, and as provided in Florida Law 81-843 paragraph (e), the Board hereby finds and determines that the supplies or materials are needed to alleviate an existing emergency and that such goods, supplies and materials cannot be obtained in sufficient time if bids, public notice and advertisement are required.

PASSED AND ADOPTED this 24th day of October, 1989 by the Board of County Commissioners of St. Johns County, Florida.

BOARD OF COUNTY COMMISSIONERS
OF ST. JOHNS COUNTY, FLORIDA

By: 
Its Chairman

ATTEST: CARL "BUD" MARKEL, CLERK

By: 
Deputy Clerk



CAPITAL PETROLEUM EQUIPMENT CO.

Div. of Connies Enterprises, Inc.

SALES - SERVICE - INSTALLATION

P. O. BOX 11238
JACKSONVILLE, FLORIDA 32239

PHONE 904 / 353-0604
FAX (904) 355-1525

GASOLINE SYSTEMS
CONSTRUCTION
MAINTENANCE

SERVICE STATION
& PLANT EQUIPMENT
SALES-SERVICE

JOB NAME St. Johns Co- Courthouse

ADDRESS

ENGINEER Attn; Mr Wayne Pacetti

DATE October 17, 1989

DATE OF PLANS

We are pleased to submit an estimate on above named job for the following:

- 1- Obtain Permit
2- Intorcor line & 10,000 gallon tank with armor shield tank lining and install overfill protection, spill containment manhole and cathodic protection for tanks and lines
3-Form and pour concrete back over excavated area.
4-Install 4-4' monitoring wells
5-Petro-Tite test system

Total- \$8,900.00

Note:

- A- Tank to be pumped out by others.
B- If existing tank cannot be used a \$1400.00 breakout and test will be apply.

All of the above labor, material and services to be performed for the sum of \$ payable as follows:
Terms Net Cash on completion of job.

As further conditions to this estimate, it is understood that we will not be responsible for delays caused by conditions beyond our control; that this proposal is void if not accepted within 30 days from this date; that any alteration or deviation from the above named items or either of them will become an extra charge over and above the sum quoted above; that this estimate when signed by us and accepted by you constitutes an entire and binding contract between us. Purchaser hereby agrees that all materials and equipment remains the property of the Seller until paid for, and the Seller reserves the right to repossess all or any portion of the material and/or equipment under this contract, if payments for such items are delinquent by more than 30 days from date of first invoice. That if any obligation hereunder is enforced by action at law or in equity then the party against whom such is enforced agrees to pay all costs including reasonable attorney's fees.

CAPITAL PETROLEUM EQUIPMENT CO.

Respectfully submitted

By

ACCEPTANCE OF ESTIMATE

The foregoing terms, conditions and specifications are hereby accepted and agreed to as a valid and binding contract and hereby authorize you to execute the same.

Dated this day of A.D. 19

ORIGINAL - To Be Returned To CAPITAL PETROLEUM EQUIPMENT CO., P. O. Box 11238, Jacksonville, Florida 32239
DUPLICATE - To Be Retained By Customer

FLORIDA EQUIPMENT SALES, INC.
INDUSTRIAL & PETROLEUM

3626 Phoenix Avenue
P.O. Box 3871
Jacksonville, Florida 32206

DATE: 10/16/89
TO : St. John's County Court House (COMPANY NAME/STATE)
ATTN: Wayne Racetti (PERSON TO NOTIFY)
904-824-3717 (TELECOPY NUMBER)
1 PAGES TO FOLLOW
FROM: Florida Equipment Sales (ORIGINATOR'S NAME)
904 354-6789 (TELEPHONE NUMBER)
FAX # _____

VERIFICATION OF FAX

OPERATOR: Chuck Strickland
TIME: _____

Tel: (904) 354-6789

Wats: (800) 226-0789

FLORIDA EQUIPMENT SALES, INC.

INDUSTRIAL & PETROLEUM

3626 Phoenix Avenue
P.O. Box 3871
Jacksonville, Florida 32206

OCTOBER 16, 1989

ST. JOHNS COUNTY COURT HOUSE
PHONE: 824-2131 EXT. 295
ATTN: WAYNE PACETTI

- INSTALL 4 2" MONITOR WELLS.
- INSTALL OVER-FILL AND SPILL CONTAINERS.
- INSPECTION FOR TANK RELINING.
- IF TANK IS OK TO RELINE INSTALL FIBERGLASS LINING.
- INSTALL NEW SUPPLY LINE TO BUILDING.
- TANK TIGHT TEST.

- INSTALLATION TOTAL: \$ 11,200.00

- 1 OPW 8061 OVER-FILL. 400.00
- 1 CLAY AND BAILY ANOID. 200.00
- 1 OPW #1 SPILL CONTAINER MANHOLE. 230.00
- 1 OPW 2" VENT CAP. 10.00
- 1 OPW CAP, ADAPTOR, AND DROP TUBE. 175.00

- EQUIPMENT TOTAL: \$ 1,015.00
- INSTALLATION TOTAL: \$ 11,200.00
- TOTAL PROJECT: \$ 12,215.00

Tel (904) 354-6789

Wats: (800) 226-0789