

RESOLUTION NO. 89-280

WHEREAS, on December 10, 1989, the Buckingham Smith Nursing Home, gas fire boiler heating system was shut down due to failure of the heat exchanger, and

WHEREAS, the said heating system has been inspected by the County Facilities Maintenance Director who finds that the system totally nonrepairable, and

WHEREAS, there are approximately fifty (50) senior citizens living in said facility requiring heat to survive, and

NOW THEREFORE, BE IT RESOLVED, the Board of County Commissioners recognizes that an emergency exists and sets aside the requirements for bidding, as provided in Chapter 81-483, Laws of Florida, paragraph (e) when such goods, supplies or materials are needed to alleviate an existing emergency and that such construction contract, or such goods, supplies or materials cannot be obtained in sufficient time if bids, public notice and advertisements are required.

BE IT FURTHER RESOLVED, that the Board of Commissioners further authorizes the County Administrator to purchase the required Heating System in the amount not to exceed \$10,000.00

ADOPTED this 12th day of December, 1989 by the St. Johns County Board of Commissioners.

BOARD OF COUNTY COMMISSIONERS  
OF ST. JOHNS COUNTY, FLORIDA

BY: Craig Maguire  
It's Chairman

ATTEST: CARL "BUD" MARKEL, CLERK

BY: Rosemary Jones  
Deputy Clerk

Deputy Clerk